CIVIL XPERTS
ISO 9001:2008
CONSULTANTS & TESTING CENTER

# 174, Sri Ranga Complex
Amrutha Nagar Main Road
New Bank Colony, Konanakunte
Bangalore - 560 062.
Mobile : +91 97429 59595
Tele/Fax : 080-2632 2565
E-mail : civilexpertsltd@gmail.com
URL : www.civilexperts.in

**NABL ACCREDITED AS PER ISO/IEC 17025:2005**

Job No.: CECTC-RV-W N-16-2015-16

Date : 06.01.2015

## TEST REPORT ON COARSE AGGREGATES
### IS 383-1970 (RA- 2002)

**Client** : **Executive Engineer,** Rajarajeshwari Nagara Division, BBMP, Bangalore.

**Agency** : **Sri.Raghavendra, contractor,** Bangalore.

**Name of Work** : Providing CC Road and Improvements to drain at 2nd A Main in Bahubali Nagara in Ward No.16.

**Reference** : EE/RRND/W.O No/78/2014-15 Dated: 07.08.2014

Date of Testing : 06.01.2015

Material : 20mm Aggregates

Total wt. of aggregates in gms = **5000**

| Is Sieve Size in mm | Weight Retained (gm) | Retained Weight in % | Cumulative Retained Weight in % | Cumulative Weight Passing in % | Spec.Limits |
|---|---|---|---|---|---|
| 40 | 0 | 0 | 0 | 100 | 100 |
| 20 | 265 | 5.3 | 5.3 | 94.7 | 95-100 |
| 10 | 2578 | 51.6 | 56.9 | 43.1 | 25-55 |
| 4.75 | 1926 | 38.5 | 95.4 | 4.6 | 0-10 |

**Note:**

1. The report shall not be reproduced, except in full, without the written approval of the laboratory.
2. The results indicated above are based on the tests carried out on the samples received in the laboratory.
3. Any Query regarding the report must be reported within 15 days from the date of testing .

For Civil Expert

Authorised Signature